



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2006010203188277

NAME AND ADDRESS OF THE APPLICANT

SCAME PARRE S.P.A.
Via Costa Erta,15-24020 PARRE (Bg)ITALY

NAME AND ADDRESS OF THE MANUFACTURER

SCAME PARRE S.P.A.
Via Costa Erta,15-24020 PARRE (Bg)ITALY

NAME AND ADDRESS OF THE FACTORY

SCAME PARRE S.P.A. (V030843)
Via Campignano,9-24020 PARRE (BG) Italy

PRODUCT NAME, MODEL AND SPECIFICATION

Surface-type Switched Socket-outlet with Interlock for Industrial Purposes
Model See Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T11918.1-2014;GB/T11918.2-2014;GB/T11918.4-2014

TYPE OF CERTIFICATION SCHEMES

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462298-2018 .

Valid from: Jul.15,2018

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Jul.15,2018

President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0117705



产品认证证书

证书编号: CQC2006010203188277

申请人名称及地址

SCAME PARRE S. P. A.
Via Costa Erta, 15-24020 PARRE (Bg) ITALY

制造商名称及地址

SCAME PARRE S. P. A.
Via Costa Erta, 15-24020 PARRE (Bg) ITALY

生产企业名称及地址

SCAME PARRE S. P. A. (V030843)
Via Campignano 9 24020 Parre (BG) Italy

产品名称和系列、规格、型号

工业用带开关、带联锁装置明装插座

型号见附件

产品标准和技术要求

GB/T11918.1-2014; GB/T11918.2-2014; GB/T11918.4-2014

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462298-2018 认证规则的要求, 特发此证。

发证日期: 2018 年 07 月 15 日

本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2018 年 07 月 15 日

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录:

第 1 页 共 2 页

证书编号: CQC2006010203188277

纸号: 117705

产品名称 (中文):

工业用带开关、带联锁装置明装插座

规格和型号:

564.3287 32A-6h/415V ~ 3P+N+PE IP67
500.3283 32A-6h/250V ~ 2P+PE IP44
500.3286 32A-6h/415V ~ 3P+PE IP44
500.3287 32A-6h/415V ~ 3P+N+ PE IP44
505.3283 32A-6h/250V ~ 2P+ PE IP67
505.3286 32A-6h/415V ~ 3P+ PE IP67
505.3287 32A-6h/415V ~ 3P+N+ PE IP67
560.3283 32A-6h/250V ~ 2P+ PE IP44
560.3286 32A-6h/415V ~ 3P+ PE IP44
560.3287 32A-6h/415V ~ 3P+N+ PE IP44
561.3283 32A-6h/250V ~ 2P+ PE IP67
561.3287 32A-6h/415V ~ 3P+N+ PE IP67
562.3283 32A-6h/250V ~ 2P+ PE IP44

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录:

第 2 页 共 2 页

证书编号: CQC2006010203188277

纸号: 117705

562.3286 32A-6h/415V ~ 3P+ PE IP44
562.3287 32A-6h/415V ~ 3P+N+ PE IP44
563.3283 32A-6h/250V ~ 2P+ PE IP67
563.3286 32A-6h/415V ~ 3P+ PE IP67
563.3287 32A-6h/415V ~ 3P+N+ PE IP67
564.3283 32A-6h/250V ~ 2P+ PE IP67
564.3286 32A-6h/415V ~ 3P+ PE IP67
567.3283 32A-6h/250V ~ 2P+ PE IP44
567.3286 32A-6h/415V ~ 3P+ PE IP44
567.3287 32A-6h/415V ~ 3P+N+ PE IP44
568.3283 32A-6h/250V ~ 2P+ PE IP67
568.3286 32A-6h/415V ~ 3P+ IP67
568.32864 32A-3h/380V ~ 50Hz/440V ~ 60Hz 3P+ PE IP67
568.3287 32A-6h/415V ~ 3P+N+ PE IP67
569.3283 32A-6h/250V ~ 2P+ PE IP67
569.3286 32A-6h/415V ~ 3P+ PE IP67
569.3287 32A-6h/415V ~ 3P+N+ PE IP67

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>