

Synthesis Report n° **ME.19.325/01B**

Bienno, 28/11/19


SYNTHESIS DOCUMENT

ASSESSMENT OF TOTAL INSULATION (CLASS II) OF PRODUCTS

ISOLATED BRAIDED SHUNT J-LINK ISOLATED BRAIDED SHUNT J-LINK PLUS

The conclusion shows that the products are in compliance with the prescription of Class II insulation according to Par. 8.4.4 of EN 61439-1:2011.

Examined products: JLK1050 / JLK5050

Inspector (<i>Massimiliano Scarsi</i>)	
---	--

Addressee: **TEKNOMEGA SRL**

Via Fermi, 27
20090 Buccinasco (MI)