Non-profit making Association nº 72.907 (Ministry of the Interior), Law 191/64.CIF:G-78493475. LICOF: R.D. 1614 on 1st of August of 1985. O.M. on 21st of May of 1991 (Ministry of Industry, Energy and Tourism)

AFITI LICOF Centre for Fire Testing and Research

Association for the Promotion of Research and Fire Safety Technology

Test Certificate

Nº: C9447/17

Applicant

SCAME PARRE SPA
Via Costa Erta 15
24020 Parre BG- Italy

Building Element

Switch disconnector
Manufacturer: SCAME PARRE SPA

References:

590.FGE4002 / 590.FEM4002
590.FGE4003 / 590.FEM4003
590.FGE4005 / 590.FEM4005
590.FGE3202 / 590.FEM3202
590.FGE3203 / 590.FEM3203
590.FGE3205 / 590.FEM3205
590.FGE2002 / 590.FEM2002
590.FGE2003 / 590.FEM2003
590.FGE2005 / 590.FEM2005
590.FGE4006 / 590.FEM4006
590.FGE3206/ 590.FEM3206
590.FGE2006 / 590.FEM2006
590.FGE10006 / 590.FEM10006
590.FGE8006 / 590.FEM8006
590.FGE6306 / 590.FEM6306
590.FGE16006 / 590.FEM16006
590.FGE12506 / 590.FEM12506
590.FGE16002 / 590.FEM16002
590.FGE16003 / 590.FEM16003
590.FGE16005 / 590.FEM16005
590.FGE12502 / 590.FEM12502
590.FGE12503 / 590.FEM12503
590.FGE12505 / 590.FEM12505
590.FGE10002 / 590.FEM10002
590.FGE10003 / 590.FEM10003
590.FGE10005 / 590.FEM10005
590.FGE8002 / 590.FEM8002
590.FGE8003 / 590.FEM8003
590.FGE8005 / 590.FEM8005
590.FGE6302 / 590.FEM6302
590.FGE6303 / 590.FEM6303
590.FGE6305 / 590.FEM6305

Test/s

Test protocol based on **EN 12101-3:2015** *"Smoke and heat control systems. Part 3: Specifications for powered smoke and heat exhaust ventilators*

Test Date

15th-Mar-18

Certificate for the reports

Test report nr 9447/17 (issued by AFITI-LICOF on 12th-Apr-2018).

Fire Resistance Classification

F_{400} 120

Classification taking as reference what is stated in the standard **EN 12101-3:2015**

Arganda del Rey, 12th of April of 2018

Digitally Signed Document

Signed: Sergio Nogueras
Technician
Fire Resistance Laboratory

Signed: Tomás de la Rosa
Technical Director
Fire Resistance Laboratory

The results of this Certificate refer solely and exclusively to the specimens tested, and not to the product in general.

The specified reports include important aspects of the test performance and development which have made it possible to obtain the aforementioned Fire Resistance classification. This certificate should be used together with the referenced reports.

Cancellation or modification of the aforementioned reports implies cancellation or modification of this certificate.

HEAD OFFICE & LABORATORIES: Camino del Estrechillo, 8 E-28500 Arganda del Rey · Madrid (Spain)

CENTRAL OFFICE & LABORATORIES: C/ Río Estenilla, s/n · P.I. Sta. Mª de Benquerencia E-45007 Toledo (Spain)

☎ +34 902 112 942
🖷 +34 901 706 587
@ licof@afiti.com
www.afiti.com